

BID NUMBER #23141

Project: Mill Creek WRF UV Disinfection Replacement

Subject: Existing Siding

Date: November 21, 2023

GENERAL QUESTIONS:

Is information available on the type of siding that is on the existing building?

RESPONSE:

Description of existing siding provided by the project architect is as follows:

Painted steel, roll formed on site. Dutchlap, 10" high (must be field verified) with three ribs, wood-grain texture.

As-built record information is not available for the existing siding.

Photos of the existing siding are below.

