

Project: Countryside Manon Water Main Replacement
Project #: PW2020.094
Bid Number: #24220
Addendum #2
Date: January 31, 2024

QUESTIONS RECEIVED

Question 5: The bid sheet shows 63 near svc's and 70 far services. I do not see any services to be replaced on the prints. Where are the services to be replaced?

Answer 5: The plan sheets include locations of all the existing located water service buffalo boxes; these are shown using the water service buffalo box symbology as shown on the cover sheet of the plans. Also, on the plan sheets next to the water service buffalo box symbol, the letters "BB" are included to note "Buffalo Box". The bid form items No.9 and No.10 note 1-Inch Water Service Reconnection Near or Far. The construction detail for water service reconnections is shown on sheet 16 of the plans and shall be installed as outlined in the specification section 02621. The location of the proposed connection to the water main and proposed location of the service box are not shown on the plans as these shall be installed in a manner of least disturbance and/or shortest distance and located generally at the same location of the existing service box.