

**Project: Countryside Manon Water Main Replacement**  
**Project #: PW2020.094**  
**Bid Number: #24220**  
**Addendum #3**  
**Date: February 6, 2024**

**QUESTIONS RECEIVED**

Question 6: Can you tell us what Item # 20 (12-Inch CA6 Granular Base, Grade 8 (Roadway Removal/Replacement) is for? We cannot find it in the spec.

Answer 6: Item 20 represents the CA-6 stone that is required to be installed at a depth of 12" as pavement base for all roadway pavement removal and replacement. The CA-6 represented in item 20 will be placed above/on top of the granular trench backfill. The Typical Trench and Bedding Detail on Sheet 16 includes a pavement restoration note that specifies the pavement requirements.